

Schena, Cristeen

From: Aram Varjabedian <avarjabedian@woodardcurran.com>
Sent: Saturday, December 16, 2017 11:09 AM
To: tberardinelli@town.hull.ma.us; Bill Boornazian; david.burns (david.burns@state.ma.us); Jim Dow; Frank Cavaleri; jstruzziery@town.hull.ma.us; jsullivan (jsullivan@town.hull.ma.us); Kate Roosa; kbornheim (kbornheim@town.hull.ma.us); Krahforst, Chris (ckrahforst@town.hull.ma.us); Lemnios, Philip (plemnios@town.hull.ma.us); coconnor@town.hull.ma.us; Robert Scott; Turin, David
Subject: RE: Hull, MA - MA0101231 - Preliminary Notification of SSO - 262 Atlantic Ave.
Attachments: 20171215_114423_resized.jpg; 20171215_124615_resized.jpg; 20171215_171626_resized.jpg; 12-15-2017-SEMS-Blockage-and-Backup-262-Atlantic-ave-MH-surcharged.pdf

Good morning:

Yesterday, December 15th, at 11:30am, while out performing daily pump station rounds/inspections our operator Eric Sutton observed a wet area around a sanitary manhole on Atlantic Ave near #262. **[MH 20928A]** Upon further investigation, the manhole was found to be surcharged. The small amount of sewage was limited to around the sewer cover area, and there was not any run-off to nearby catch basins.

Calls were made for outside contractor assistance immediately. Rosano-Davis Pumping responded in approximately 30 minutes and the surcharged manhole was pumped down – total approx. gallons pumped out 500 to 1000 gallons] to stop the SSO from occurring and lower the level in the manhole down to the invert, while National Water Main Co. was contacted and to be on route to jet out the plugged gravity sewer line. The surcharged manhole structure shallow and about 3.5 to 4 from the street grade to the invert.

After sewer jetting of the line was completed by 3:40pm, all conditions were reported to be normal. There were no additional reported affected areas.

A full SSO report will follow. A couple of photos are attached that show the affected area, which was very small. Should you have any questions, please don't hesitate to contact me at 781-925-0906.

Sincerely,

Aram

Aram Varjabedian
Plant Manager
Hull Wastewater Treatment Facility
1111 Nantasket Avenue | Hull, MA 02045
Phone 781.925.0906 | Fax 781.925.3056 | Cell 339.214.8334
www.woodardcurran.com



COMMITMENT & INTEGRITY DRIVE RESULTS

Aram

Aram Varjabedian
Plant Manager
Hull Wastewater Treatment Facility
1111 Nantasket Avenue | Hull, MA 02045
Phone 781.925.0906 | Fax 781.925.3056 | Cell 339.214.8334
www.woodardcurran.com



COMMITMENT & INTEGRITY DRIVE RESULTS